



## DRAFT ASSAM

## ECO-NIWAS SAMHITA 2021

(Energy Conservation Building Code for Residential Buildings)

PART I: BUILDING ENVELOPE









# CONTENTS

| iii |

List of to	ables	iv
List of fi	igures	v
Commi	ittees and Working Groups	vi
СНАР	TER 1 - INTRODUCTION	1
СНАР	TER 2 - SCOPE	4
CHAP	TER 3 - CODE PROVISIONS	
3.1	Openable Window-to-Floor Area Ratio (WFR <sub>op</sub> )	6
3.2	Visible Light Transmittance (VLT)	7
3.3	Thermal Transmittance of Roof (U <sub>roof</sub> )	7
3.4	Residential envelope transmittance value (RETV) for building envelope (except roof) for four climate zones, namely, Composite Climate, Hot-Dry	
25	Climate, Warm-Humid Climate, and Temperate Climate	8
3.5	Thermal transmittance of building envelope (except roof) for cold climate ( $U_{\text{envelope, cold}}$ )	10
CHAP	TER 4 - CODE COMPLIANCE	12
ANNE	XURES	
An	nnexure 1 Terminology and Definitions	14
An	nexure 2 Climatic zone and classification of cities	18
An	nexure 3 Calculation of openable window-to-floor area ratio (WFR <sub>op</sub> )	21
	nexure 4 Calculation of window-to-wall ratio (WWR)	
An	nexure 5 Calculation of thermal transmittance (U value) of roof and wall	23
An	nexure 6 Orientation Factor	27
An	nnexure 7 Calculation of Equivalent SHGC	28
	nnexure 8 Examples of Code Compliance	
An	nnexure 9 Guidelines for Design for Natural Ventilation	52
An	nexure 10 Cool Roof and Roof Gardens	56

#### LIST OF TABLES

Table	1	Minimum requirement of window-to-floor area ratio (WFR <sub>op</sub> )	6
Table	2	Minimum visible light transmittance (VLT) requirement	7
Table	3	Coefficients (a, b, and c) for RETV formula	10
Table	4	Details of Latitude & Longitude of Assam	19
Table	5	Default openable area to opening area ratio	21
Table	6	Values of surface film thermal resistance for U-value calculation	22
Table	7	Thermal properties of building and insulating materials	23
Table	8	Values of unventilated air layer thermal resistance for U-value calculation	26
Table	9	Orientation factor $(\omega)$ for different orientations.	27
Table	10	External Shading Factor for Overhang (ESF $_{overhang}$ ) for LAT $\geq 23.5$ °N	30
Table	11	External Shading Factor for Overhang (ESF <sub>overhang</sub> ) for LAT<23.5 N	
Table	12	External Shading Factor for Side Fin-Right (ESF $_{right}$ ) for LAT $\geq$ 23.5 °N	
Table	13	External Shading Factor for Side Fin-Right (ESF <sub>right</sub> ) for LAT<23.5 N	33
Table	14	External Shading Factor for Side Fin-Left (ESF $_{left}$ ) for LAT $\geq$ 23.5 $^{\circ}N$	34
Table	15	External Shading Factor for Side Fin-Left (ESF <sub>left</sub> ) for LAT<23.5 N	35
Table	16	Details of exposed doors, windows, and ventilators (Example 1)	38
Table	17	Details of construction material (Example 1)	39
Table	18	Envelope areas of the building (Example 1)	40
Table	19	Openable area calculation (Example 1)	40
Table	20	Calculation of window-to-wall ratio (Example 1)	41
Table	21	Roof construction details (Example 1)	42
Table	22	Calculation of envelope area for each orientation (Example 1)	43
Table	23	Calculation of equivalent SHGC of non-opaque	
		openings for each orientation (Example 1)	
Table		Calculation of 3 terms of RETV formula	
Table	25	Details of exposed door, windows, and ventilators (Example 2)	
Table		Details of construction material (Example 2)	
Table	27	Envelope areas of the building (Example 2)	
Table		Calculation of openable areas (Example 2)	
Table	29	Calculation of window-to-wall ratio (Example 2)	49
Table	30	Minimum requirement of window-to-floor area ratio, WFR <sub>on</sub>	51

#### LIST OF FIGURES

Figure	1	Walls included in the definition of building envelope	14
Figure	2	Projection factor, overhang	15
Figure	3	Projection factor, side fin	16
Figure	4	Solar heat gain through a non-opaque component	16
Figure	5	Climate zone map of Assam	18
Figure	6	District map of Assam	19
Figure	7	Primary orientations for determining the orientation factor $\omega$	27
Figure	8	Layout plan of the project (Example 1)	37
Figure	9	Plan of a typical DU (Example 1)	38
Figure 1	0	Building for compliance check on the layout of project (Example 1)	39
Figure 1	1 (	Openings on adjacent or opposite external walls for cross ventilation (Guideline)	52
Figure 1	2 (	Openings on external wall and internal wall for cross ventilation (Guideline)	52
Figure 1	3	Two windows on single external wall (Guideline)	53
Figure 1	14 /	Adding ventilators above windows improves ventilation especially	
		when only single external wall is available for openings (Guideline)	53

Bureau of Energy Efficiency (BEE)

DRAFT AENS 2021

| v |



## **Committees and Working Groups**

#### Steering Committee

Abhay Bakre, Director General, Bureau of Energy Efficiency (Chair)

Saurabh Diddi, Director, Bureau of Energy Efficiency (Convenor)

Arijit Sengupta, Director, Bureau of Energy Efficiency (BEE)

Madhurima Madhay, Bureau of Indian Standards (BIS)

Amor Kool, Bureau of Indian Standards (BIS)

Vijay Garg, Council of Architecture (COA)

V P Singh, Ministry of Housing and Urban Affairs (MoHUA), Government of India

B K Bhatt, Ministry of New and Renewable Energy (MNRE), Government of India

R Srinivas, Town and Country Planning Organisation (TCPO)

S Surendra, Town and Country Planning Organisation (TCPO)

Pawan Kumar, Town and Country Planning Organisation (TCPO)

Anand Shukla, Swiss Agency for Development and Cooperation (SDC)

Abdullah Nisar Siddiqui, Bureau of Energy Efficiency (BEE)

Shatakshi Suman, Bureau of Energy Efficiency (BEE)

Anju Singh, Bureau of Energy Efficiency (BEE)

Karl May, Deutsche Gesellschaft für Internationale Zusammenarbeit (GIZ)

S Vikash Ranjan, Deutsche Gesellschaft für Internationale Zusammenarbeit (GIZ)

Govinda Somani. Deutsche Gesellschaft für Internationale Zusammenarbeit (GIZ)

Wesley Wojtas, Deutsche Gesellschaft für Internationale Zusammenarbeit (GIZ)

Apurva Chaturvedi, United States Agency for International Development (USAID)

Naveen Akkina, Indian Green Building Council (IGBC)

Punit Agarwal, Indian Green Building Council (IGBC)

Mili Majumdar, Green Building Certification Inc. (GBCI)

Apoory Vij, Green Building Certification Inc. (GBCI)

Suhaas Mathur, Green Building Certification Inc. (GBCI)

Yatin Choudhary, The Energy and Resources Institute (TERI)

Pardeep Chauhan, The Energy and Resources Institute (TERI)

Disha Sharma, The Energy and Resources Institute (TERI)

Sonia Rani, The Energy and Resources Institute (TERI)

Alok K Modi, Gujarat Guardian Ltd (GGL)

Sourabh Kankar, Gujarat Guardian Ltd (GGL)

R Subramanian, Glazing Society of India (GSI)

Gopal Ganatra, Glazing Society of India (GSI)

G N Gohul Deepak, Glazing Society of India (GSI)

N Murali, Glazing Society of India (GSI)

Aditi Salway, The All India Glass Manufacturers' Federation (AIGMF)

Ragini Goswami, International Finance Corporation (IFC)

Ashok Lall, Ashok B, Lall Architects

Prashant Bhanware, Indo-Swiss Building Energy Efficiency Project (BEEP)

Saswati Chetia, Indo-Swiss Building Energy Efficiency Project (BEEP)

Vernica Prakash Kapoor, Indo-Swiss Building Energy Efficiency Project (BEEP)

Sameer Maithel, Indo-Swiss Building Energy Efficiency Project (BEEP)

#### **Technical Committee**

Saurabh Diddi, Director, Bureau of Energy Efficiency (Chair and Convenor)

Arijit Sengupta, Director, Bureau of Energy Efficiency (BEE)

Anju Singh, Bureau of Energy Efficiency (BEE)

Madhurima Madhay, Bureau of Indian Standards (BIS)

Ujjwal Mitra, Central Public Works Department (CPWD)

Rajeev Sharma, Central Public Works Department (CPWD)

R Srinivas, Town and Country Planning Organisation (TCPO).

Harpal Dave, Town and Country Planning Organisation (TCPO)

Anand Shukla, Swiss Agency for Development and Cooperation (SDC)

Tanmay Tathagat, Environmental Design Solutions (EDS) Global (P) Ltd

Piyush Varma, EDS Global (P) Ltd

Ashok Lall, Ashok B. Lall Architects Salil Mohan, Ashok B. Lall Architects

Rajan Rawal, Centre for Environmental Planning and Technology (CEPT)

Vishal Garg, International Institute of Information Technology (IIIT)

Jyotirmay Mathur, Malaviya National Institute of Technology (MNIT)

Shweta Manchanda, School of Planning and Architecture (SPA)

Abdullah Nisar Siddiqui, Bureau of Energy Efficiency (BEE)

Meenal Anand, Bureau of Energy Efficiency (BEE)

Karl May, Deutsche Gesellschaft für Internationale Zusammenarbeit (GIZ)

S Vikash Ranjan, Deutsche Gesellschaft für Internationale Zusammenarbeit (GIZ)

Govinda Somani, Deutsche Gesellschaft für Internationale Zusammenarbeit (GIZ)

Naveen Akkina, Indian Green Building Council (IGBC)

Shivraj Dhaka, Indian Green Building Council (IGBC)

Praveen Soma, Indian Green Building Council (IGBC)

Apoorv Vij, Green Building Certification Inc. (GBCI)

Suhaas Mathur, Green Building Certification Inc. (GBCI

Yatin Choudhary, The Energy and Resources Institute (TERI)

Pradeep Kumar, The Energy and Resources

Institute (TERI)

G N Gohul Deepak, Glazing Society of India (GSI)R Subramanian, Glazing Society of India (GSI)

N Murali, Glazing Society of India (GSI)

S Senthil Kumar, The All India Glass Manufacturers' Federation (AIGMF)

Aditi Salway, The All India Glass Manufacturers' Federation (AIGMF)

Rohit Jain, Indian Institute of Architects (IIA)

Pierre Jaboyedoff, Indo-Swiss Building Energy Efficiency Project (BEEP)

Prashant Bhanware, Indo-Swiss Building Energy Efficiency Project (BEEP)

Saswati Chetia, Indo-Swiss Building Energy Efficiency Project (BEEP)

Vernica Prakash Kapoor, Indo-Swiss Building Energy Efficiency Project (BEEP)

Sameer Maithel, Indo-Swiss Building Energy Efficiency Project (BEEP)

#### **Development Team**

#### Bureau of Energy Efficiency

Abhay Bakre, Director General Saurabh Diddi, Director

Arijit Sengupta, Director

Abdullah Nisar Siddiqui, Project Manager Anju Singh, Project Engineer

#### Swiss Agency for Development and Cooperation

Anand Shukla

#### Indo-Swiss Building Energy Efficiency Project

Pierre Jaboyedoff, Effin'art Sarl

Sameer Maithel, Greentech Knowledge Solutions Pvt. Ltd Prashant Bhanware, Greentech Knowledge Solutions

Pvt. Ltd Saswati Chetia, Greentech Knowledge Solutions Pvt. Ltd

Vernica Prakash Kapoor, Greentech Knowledge Solutions Pvt. Ltd Satyendra Rana, Greentech Knowledge

Solutions Pvt. Ltd.

Ashok Lall, Ashok B. Lall Architects Salil Mohan, Ashok B. Lall Architects



# Chapter 1

### INTRODUCTION

- 1.1. India's Intended Nationally Determined Contributions (INDCs) aim to reduce the emissions intensity of its gross domestic product (GDP) by 33 to 35 percent by 2030 from 2005 level. Any effort to achieve this target is contingent upon the increase in efficiency of energy use across all sectors, especially in the building sector. The building sector in India consumes over 30% of the total electricity consumed in the country annually and is second only to the industrial sector as the largest emitter of greenhouse gases (GHGs).
- Out of the total electricity consumed in the building sector, about 75% is used inresidential buildings. The gross electricity consumption in residential buildings hasbeen rising sharply over the years. For instance, the consumption figure rose to about 260 TWh in 2016-17 from about 55 TWh in 1996-97.³ That is an increase by morethan four times in 20 years. Projections show it rising to anywhere between 630 and 940 TWh by 2032.⁴ Among various reasons, increased use of decentralized room-based air-conditioning units in homes for thermal comfort is an important reasoncontributing to this rapid increase in the electricity use in residential buildings. The demand for air-conditioning will continue its exponential growth with improvementin household incomes and will become the dominant contributor of GHG emissionsnation-wide owing to increased electricity consumption. This situation calls for an immediate energy conservation action plan.
- 13. Energy codes for new buildings are an important regulatory measure for usheringenergy efficiency in the building sector. They are particularly relevant for countries like India where the building stock is growing rapidly. The commercial sector amongbuildings has been addressed by the Energy Conservation Building Code (ECBC) for Commercial Buildings. Given the current and anticipated rapid growth in the residential building stock across India and the consequent opportunities as well as thenecessity for energy conservation in this sector, the Energy Conservation Code for Residential Buildings is established by the Ministry of Power.

India's Intended Nationally Determined Contribution. Available at http://www4.unfccc.int/submissions/INDC/Published% 20Documents/India/1/INDIA% 20INDC% 20TO% 20UNFCCC.pdf (accessed on 1 May 2018)

Ministry of Statistics and Programme Implementation (MoSPI). 2018. Energy Statistics 2018. New Delhi: MoSPI, Government of India.

<sup>&</sup>lt;sup>3</sup> Central Electricity Authority (CEA). 2017. Growth of Electricity Sector in India from 1947-2017. New Delhi: CEA, Govern- ment of India.

<sup>&</sup>lt;sup>4</sup> NITI Aayog. *India Energy Security Scenario*, 2047. New Delhi: NITI Aayog, Government of India. Available at http://indiaenergy.govin/iess/default.php (accessed on 1 May 2018).

CHAPTER 1 INTRODUCTION

Building envelope consists of walls, roof, and fenestration (openings including windows, doors, vents, etc.). Design of building envelope influences heat gain/loss, natural ventilation, and daylighting, which, in turn, determines indoor temperatures, thermal comfort, and sensible cooling/heating demand.

- 15. Most parts of India have cooling-dominated climates. Consideration of heat gain isoften not given sufficient importance during residential building design. It is seenthat current practices of residential building design and construction show a largevariation in heat gains and hence in the sensible cooling demand. Depending on the envelope design and construction adopted for residential buildings located in aparticular climate zone, the minimum and maximum sensible cooling demand canvary by as much as 1:3.7
- 16. Energy Conservation Building Code Residential (ECBC-R) (Part I: Building Envelope) has been prepared to set minimum building envelope performance standards to limit heat gains (for cooling dominated climates) and to limit heat loss (for heating dominated climates), as well as for ensuring adequate natural ventilationand daylighting potential. The code provides design flexibility to innovate and varyimportant envelope components such as wall type, window size, type of glazing, and external shading to windows to meet the compliance.
- 17. The code is applicable to all residential buildings and residential parts of 'mixedland-use projects', both built on a plot area of ≥500 m². However, states and municipal bodies may reduce the plot area based on the prevalence in their area of juris- diction. This provision is kept to take into account the prevalent plot sizes and housing types in different states, enabling the inclusion of a greater percentage of new multi-dwelling unit residential buildings within the scope of this code. (Please refer paragraph 2.4.)
- Building envelope has the highest impact on thermal comfort, and consequently on the energy use in residential buildings. The envelope is also a permanent component of the building with the longest life cycle. An early introduction of this code would improve the design and construction of new residential building stock beingbuilt currently and in the near future, thus significantly curtailing the anticipated

Bureau of Indian Standards (BIS). 1987 and 2016. *Handbook on Functional Requirements of Buildings (Other than Industrial Buildings) SP: 41 (S & T) - 1987*, and National Building Code (NBC) of India 2016. New Delhi: BIS.

These are climates where the ambient temperatures are high during major part of the year and mechanical space cooling is required for thermal comfort.

Bureau of Energy Efficiency (BEE). 2014. Design Guidelines for Energy-Efficient Multi-Storey Residential Buildings (Warm-Humid Climate). New Delhi: BEE.

These are climates where the ambient temperatures are low during major part of the year and mechanical space heating is required for thermal comfort.

INTRODUCTION CHAPTER 1

Energy demand for comfort cooling in times to come. This critical investment inenvelope design and construction made today will reap benefits of reduced GHGemissions for the lifetime of the buildings.

19. Part I – Building Envelope of ECBC-R is designed in a simple-to-apply format, requiring only simple calculations based on inputs from the architectural design drawings ofbuildings. This can be used by architects and engineers and will not require any simulation software. This also enables the code to be readily adopted in the buildingbye-laws. A compliance tool is also available on BEE website to aid in the calculations and compliance check.

1.10. Part I – Building Envelope is the first part of ECBC-R. It is envisaged that new parts willbe added to address other aspects, such as energy efficiency in electro-mechanical equipment for building operation, renewable energy generation, and embodied energy of building materials and structural systems.





**SCOPE** 

- 21 The code sets minimum performance standards for building envelope to limit heatgains (for cooling dominated climates) and limit heat loss (for heating dominated climates) through it. The code gives the following provisions to this effect:
  - Building Envelope (except roof)
    - Maximum value of residential envelope transmittance value (RETV) for building envelope (except roof) applicable for four climate zones<sup>9</sup>, namely, Composite Climate, Hot-Dry Climate, Warm-Humid Climate, and Temperate Climate.
    - Maximum value of thermal transmittance of building envelope (except roof) for Cold Climate zone (U<sub>envelope cold</sub>).
  - Roof: Maximum value of thermal transmittance of roof  $(U_{roof})$  for all climatezones.
- The code sets minimum building envelope performance standard for adequate natural ventilation potential by specifying minimum openable window-to-floor area ratio (WFR<sub>op</sub>).
- 23 The code sets minimum building envelope performance standard for adequate daylight potential by specifying minimum visible light transmittance (VLT) for the non-opaque building envelope components.
  - The code applies to (a) 'Residential buildings' built on a plot area  $\ge 500 \text{ m}^2$  and (b) Residential part of 'Mixed land-use building projects', <sup>10</sup> built on a plot area <sup>11</sup> of  $\ge 500 \text{ m}^2$ .
- 'Residential building' 12 includes any building in which sleeping accommodation is provided for normal residential purposes with or without cooking or dining or both facilities. This definition includes:
- One or two family private dwellings: These shall include any private dwelling, which is occupied by members of one or two families and has a total sleeping accommodation for not more than 20 persons.

<sup>&</sup>lt;sup>9</sup> For climate classification, see Annexure 2.

However, residential accommodation in a building, where the carpet area of the residential part is not more than 30 m² for caretakers or persons employed in connection with the building, is exempted.

States and municipal bodies may reduce the plot area based on the prevalence in their area of jurisdiction.

Adapted from Bureau of Indian Standards (BIS), 2016. National Building Code of India 2016. New Delhi: BIS

SCOPE CHAPTER 2

Apartment houses: These shall include any building or structure in which living quarters are provided for three or more families, living independently of each other and with independent cooking facilities. This also includes 'Group Housing'.

The following are excluded from the definition of 'residential building' for the purpose of this code.

- Lodging and rooming houses: These shall include any building or group of buildings under the same management in which separate sleeping accommodation on transient or permanent basis, with or without dining facilities but without cooking facilities for individuals, is provided. This includesinns, clubs, motels, and guest houses.
- Dormitories: These shall include any building in which group sleeping accommodation
  is provided, with or without dining facilities for persons who are not members of the same
  family, in one room or a series of closely associated rooms under joint occupancy and
  single management. For example, school and college dormitories, students, and other
  hostels and military barracks.
- Hotels: These shall include any building or group of buildings under single management, in which sleeping accommodation is provided, with or without dining facilities.

Bureau of Energy Efficiency (BEE)

DRAFT AENS 2021

| 5 |



## **CODE PROVISIONS**

#### 3.1 Openable Window-to-Floor Area Ratio (WFR<sub>on</sub>)

- 3.1.1 Openable window-to-floor area ratio ( $WFR_{op}$ ) indicates the potential of using external air for ventilation. Ensuring minimum  $WFR_{op}$  helps in ventilation, improvement inthermal comfort, and reduction in cooling energy.
- The openable window-to-floor area ratio ( $WFR_{op}$ ) is the ratio of openable area to the carpet area of dwelling units.

$$WFR_{op} \stackrel{\square}{\underbrace{A_{openable}}}_{A_{carpet}} \dots (1)$$

where.

 $WFR_{on}$ : openable window-to-floor area ratio

a copenable area (m²); it includes the openable area of all windows and ventilators, opening directly to the external air, an open balcony, 'verandah', corridor or shaft; and the openable area of the doors opening directly into an open balcony.

Exclusions: All doors opening into corridors. External doors on ground floor, for example, ground-floor entrance doors or back-yard doors.

: carpet area of dwelling units  $(m^2)$ ; it is the net usable floor area of a dwelling unit,  $A_{carpet}$  excluding the area covered by the external walls, areas under services shafts, exclusive balcony or verandah area and exclusive open terrace area, but includes the area covered by the internal partition walls of the dwelling unit.  $^{13}$ 

313 The openable window-to-floor area ratio  $(WFR_{op})$  shall not be less than the values<sup>14</sup> given in Table 1.

**TABLE 1** Minimum requirement of window-to-floor area ratio (WFR<sub>op</sub>)

Climatic zone	Minimum WFR <sub>op</sub> (%)
Warm-Humid	16.66
Cold	8.33

SOURCE Adapted from Bureau of Indian Standards (BIS). 2016. National Building Code of India 2016. New Delhi: BIS.

The Real Estate (Regulation and Development) Bill, 2016 (as passed by the Rajya Sabha on the 10 March 2016). Avail-able at http://164.100.474/BillsTexts/RSBillTexts/PassedRajyaSabha/realest-238-RSP-E.pdf (accessed on 1 May 2018)

To comply with the Code, WFR<sub>op</sub> (%) values shall be rounded off to two decimal places in accordance with IS 2: 1960 'Rules for rounding off numerical values'.

#### 32 Visible Light Transmittance (VLT)

321 Visible light transmittance (VLT) of non-opaque building envelope components (transparent/translucent panels in windows, doors, ventilators, etc.), indicates the potential of using daylight. Ensuring minimum VLT helps in improving daylighting, thereby reducing the energy required for artificial lighting.

The glass used in non-opaque building envelope components (transparent/translucent panels in windows, doors, etc.) shall comply with the requirements given in Table 2. The VLT requirement is applicable as per the window-to-wall ratio (WWR) of the building. WWR is the ratio of the area of non-opaque building envelope components of dwelling units to the envelope area (excluding roof) of dwelling units.

$$WWR = \frac{A_{non-opaque}}{A_{envelope}} \qquad \dots (2)$$

TABLE 2 Minimum visible light transmittance (VLT) requirement<sup>15</sup>

Window-to-wall ratio (WWR) <sup>16</sup>	Minimum VLT 17	
0-0.30	0.27	
0.31—0.40	0.20	
0.41—0.50	0.16	
0.51—0.60	0.13	
0.61-0.70	0.11	

SOURCE Bureau of Indian Standards (BIS). 2016. National Building Code of India 2016. New Delhi: BIS.

#### 3.3 Thermal Transmittance of Roof (U<sub>roof</sub>)

- 33.1 Thermal transmittance  $(U_{roof})$  characterizes the thermal performance of the roof of a building. Limiting the  $U_{roof}$  helps in reducing heat gains or losses from the roof, thereby improving the thermal comfort and reducing the energy required for cooling or heating.
- Thermal transmittance of roof shall comply with the maximum  $U_{roof}$  value of 1.2 W/m<sup>2</sup>.K.

It is advised that a) the WWR ≤ 0.15, minimum VLT should be 40% and b) the WWR in residential buildings may not exceed 0.40.

To comply with the Code, VLT values shall be rounded off to two decimal places in accordance with IS 2: 1960 'Rules for rounding off numerical values'.

To comply with the Code, WWR values shall be rounded off to two decimal places in accordance with IS 2: 1960

<sup>&#</sup>x27;Rules for rounding off numerical values'.

333 The calculation  $^{18}$  shall be carried out, using Equation 3 as shown below.

$$\mathbf{U}_{roof} = \frac{1}{A_{roof}} \left[ \sum_{i=1}^{n} \left( U_i \times A_i \right) \right] \qquad ...(3)$$

where.

 $U_{roof}$ : thermal transmittance of roof (W/m<sup>2</sup>.K)

 $A_{roof}$ : total area of the roof (m<sup>2</sup>)

 $U_{i}$ : thermal transmittance values of different roof constructions (W/m<sup>2</sup>.K)

 $A_{\perp}$ : areas of different roof constructions (m<sup>2</sup>)

Residential envelope transmittance value (RETV) for building envelope (except roof) for four climate zones, namely, CompositeClimate, Hot-Dry Climate, Warm-Humid Climate, and Temperate Climate

Residential envelope heat transmittance (*RETV*) is the net heat gain rate (over the cooling period) through the building envelope (excluding roof) of the dwelling units divided by the area of the building envelope (excluding roof) of the dwelling units. Its unit is W/m<sup>2</sup>.

*RETV* characterizes the thermal performance of the building envelope (except roof). Limiting the *RETV* value helps in reducing heat gains from the building envelope, thereby improving the thermal comfort and reducing the electricity required forcooling.

*RETV* formula takes into account the following:

- Heat conduction through opaque building envelope components (wall, opaquepanels in doors, windows, ventilators, etc.),
- Heat conduction through non-opaque building envelope components (trans parent/translucent panels of windows, doors, ventilators, etc.),
- Solar radiation through non-opaque building envelope components (transparent/translucent panels of windows, doors, ventilators, etc.)
- The *RETV* for the building envelope (except roof) for four climate zones, namely, Composite Climate, Hot-Dry Climate, Warm-Humid Climate, and Temperate Climate, shall comply with the maximum RETV<sup>19</sup> of 15 W/m<sup>2</sup>.

Bureau of Energy Efficiency (BEE) DRAFT AENS 2021

8

To comply with the Code, U value shall be rounded off to one decimal places in accordance with IS 2: 1960 'Rules for rounding off numerical values'.

BEE plans to improve the RETV norm to 12 W/m<sup>2</sup> in the near future and the building industry and regulating agencies are encouraged to aim for it.

<sup>&#</sup>x27;Rules for rounding off numerical values'.

The RETV calculation<sup>20</sup> of the building envelope (except roof) shall be carried out, using Equation 4 as shown below.

$$\begin{aligned} \text{RETV} &= \frac{1}{A_{\text{envelope}}} \times \left[ \left\{ a \times \sum_{i=1}^{n} \left( A_{\text{opaque1}} \times U_{\text{opaque1}} \times \omega_{1} \right) \right\} + \left\{ b \times \sum_{i=1}^{n} \left( A_{\text{non-opaque1}} \times U_{\text{opaque1}} \times \omega_{1} \right) \right\} + \left\{ c \times \sum_{i=1}^{n} \left( A_{\text{non-opaque1}} \times \text{SHGC}_{\text{eq1}} \times \omega_{1} \right) \right\} \right] \end{aligned}$$
...(4)

where,

 $A_{envelope}$ : envelope area (excluding roof) of dwelling units (m<sup>2</sup>). It is the gross

external wall area (includes the area of the walls and theopenings such

as windows and doors).

A : areas of different opaque building envelope components (m<sup>2</sup>)

 $U_{\it opaque;}$  : thermal transmittance values of different opaque building enve-lope

components (W/m<sup>2</sup>.K)

 $A_{non-opaque}$ : areas of different non-opaque building envelope components  $(m^2)$ 

 $U_{non-opaque_i}$ : thermal transmittance values of different non-opaque buildingenvelope

components (W/m<sup>2</sup>.K)

 $SHGC_{eq_i}$ : equivalent solar heat gain coefficient values of different

non-opaque building envelope components (refer to Annexure 7)

orientation factor of respective opaque and non-opaque building envelope components; it is a measure of the amount of direct and diffused solar radiation that is received on the vertical surface in a specific

orientation (values are given in Annexure 6)

To comply with the Code, RETV value shall be rounded off to nearest integer value in accordance with IS 2: 1960

<sup>&#</sup>x27;Rules for rounding off numerical values'.

The coefficients of RETV formula, for different climate zones (for classification, refer to Annexure 2), are given in Table 3.

TABLE 3 Coefficients (a, b, and c) for RETV formula

Climate zone	a	b	c	
Warm-Humid	5.15	1.31	65.21	
Cold	Not applicable (R	efer Section 3.5)		

## 3.5 Thermal transmittance of building envelope (except roof) for cold climate (U<sub>envelope</sub>,

cold

35.1 Thermal transmittance ( $U_{envelope, cold}$ ) characterizes the thermal performance of the building envelope (except roof). Limiting the  $U_{envelope, cold}$  helps in reducing heat losses from the building envelope, thereby improving the thermal comfort and reducing the energy required for heating.

 $U_{envelope, cold}$  takes into account the following:

- Heat conduction through opaque building envelope components (wall, opaquepanels in door, window, ventilators, etc.)
- Heat conduction through non-opaque building envelope components (trans parent/translucent panels in windows, doors, ventilators, etc.).
- 35.2 The thermal transmittance of the building envelope (except roof) for cold climateshall comply with the maximum<sup>21</sup> of 1.8 W/m<sup>2</sup>.K.
- 353 The calculation<sup>22</sup> of the building envelope (except roof) shall be carried out, using Equation 5 as shown below.

$$\mathbf{U}_{\textit{envelope,cold}} = \frac{1}{A_{\textit{envelope}}} \left[ \sum_{i=1}^{n} \left( U_i \times A_i \right) \right] \qquad ...(5)$$

where.

 $U_{envelope, cold}$ : thermal transmittance of building envelope (except roof) for coldclimate (W/m<sup>2</sup>.K)

agencies are encouraged to aim for it.

BEE plans to improve the  $U_{envelope, cold}$  norm to 12 W/m<sup>2</sup>. K in the near future and the building industry and regulating

To comply with the Code, value shall be rounded off to one decimal places in accordance with IS 2: 1960 'Rules for rounding off numerical values'.

 $A_{\it envelope}$ : Envelope area (excluding roof) of dwelling units (m²). It is the grossexternal wall area (includes the area of the walls and the openings such as windows and doors)

 $U_{i}$  : thermal transmittance of different opaque and non-opaque building envelope components  $(\mathrm{W/m^2.K})$ 

 $A_i$  : area of different opaque and non-opaque opaque building envelope components (m<sup>2</sup>)





## **CODE COMPLIANCE**

- The code is designed in a simple-to-apply format, requiring only simple calculations based on inputs from the architectural design drawings of residential buildings. This can be used by architects and engineers and will not require any simulationsoftware.
- 42 If a building project has more than one building block, each building block isrequired to comply with the code. However, for identical building blocks with thesame orientation,<sup>23</sup> the compliance has to be shown for one building block.
- The steps for checking compliance for Composite Climate, Hot-Dry Climate, Warm- Humid Climate, and Temperate Climate are as follows:
- **Step 1:** Openable window-to-floor area ratio shall comply with the minimum  $WFR_{op}$  values as given in Table 1 of paragraph 3.1.3. For calculation of  $WFR_{op}$ , refer Annexure 3.
- **Step 2:** Visible light transmittance (VLT) of non-opaque building envelope components hall comply with the minimum VLT values as given in Table 2 of paragraph 3.2.2.
  - a) For calculation of WWR, refer Annexure 4.
  - b) Refer product specifications to know the VLT of transparent/translucent panels inwindows, doors, and ventilators.
- **Step 3:** Thermal transmittance of roof shall comply with the maximum  $U_{roof}$  value of 1.2 W/m<sup>2</sup>.K (refer paragraph 3.3). To calculate the U values of roof, refer Annexure 5.
- **Step 4:** Residential envelope transmittance value (RETV) for building envelope (exceptroof) shall comply with the maximum RETV of 15 W/m<sup>2</sup> (refer paragraph 3.4)
  - a) Equation 4 is to be used for the calculation of RETV, with coefficients selectedfrom Table 3 as per the climate zone.
  - b) For calculation of WWR, refer Annexure 4.
  - c) For calculation of U values, refer Annexure 5.
  - d) For orientation factor, refer Annexure 6.
  - e) For calculation of Equivalent SHGC, refer Annexure 7.

An example of code compliance is given in Annexure 8 (Example 1).

For details of orientation, refer Annexure 6.

CODE COMPLIANCE CHAPTER 4

- 4.4 The steps for checking compliance for cold climate are as follows:
- **Step 1:** Openable window-to-floor area ratio shall comply with the minimum  $WFR_{op}$  values as given in Table 1 of paragraph 3.1.3. For calculation of  $WFR_{op}$  refer Annexure 3.
- **Step 2:** Visible light transmittance (VLT) of non-opaque building envelope components hall comply with the minimum VLT values as given in Table 2 of paragraph 3.2.2.
  - a) For calculation of WWR, refer Annexure 4.
  - b) Refer product specifications to know the VLT of transparent/translucent panels inwindows, doors, and ventilators.
- **Step 3:** Thermal transmittance of roof shall comply with the maximum  $U_{roof}$  value of 1.2 W/ m<sup>2</sup>.K (refer paragraph 3.3). To calculate the U values of roof, refer Annexure 5.
- **Step 4:** Thermal transmittance of building envelope (except roof) for cold climate shallcomply with the maximum value of  $1.8 \text{ W/m}^2$ .K (refer paragraph 3.5).
  - a) Equation 5 is to be used for the calculation of  $U_{envelope, cold}$ .
  - b) For calculation of U values, refer Annexure 5.


An example of code compliance is given in Annexure 8 (Example 2).





#### ANNEXURE 1 Terminology and Definitions

**Building Envelope:** The elements of a building that separate the habitable spaces ofdwelling units from the exterior and are exposed to the ambient (i.e., exposed directly to external air and opening into balconies). It does not include walls facing open corridorsand enclosed shafts, as well as walls of common services such as lifts and staircase. (See Figure 1. Dotted lines show the walls included in the definition of building envelope inthis code.)



**FIGURE 1** Walls included in the definition of building envelope

Carpet Area<sup>24</sup>: Carpet area is the net usable floor area of a dwelling unit, excluding the areacovered by the external walls, areas under services shafts, exclusive balcony or verandah area and exclusive open terrace area, but includes the area covered by the internal parti-tion walls of the dwelling unit.

**Envelope Area:** Envelope area (excluding roof) of dwelling units is the overall area of the building envelope (see definition 'Building Envelope'). It is the gross external wallarea (includes the area of the walls and the openings such as windows and doors), withmeasurement taken horizontally from outside surface to outside surface and measuredvertically from the top of the floor to the top of the roof.

**Non-opaque Building Envelope Components:** Non-opaque building envelope components include transparent/translucent panels in windows, doors, ventilators, etc.

**Opaque Building Envelope Components:** Opaque building envelope components include walls, opaque panels in doors, windows, ventilators, etc.


Source: The Real Estate (Regulation and Development) Bill, 2016 as passed by the Rajya Sabha on the 10 March 2016. Available at http://164.100.474/BillsTexts/RSBillTexts/PassedRajyaSabha/realest-238-RSP-E.pdf (accessed on 1 May 2018)

**Openable Window-to-Floor Ratio** (WFR<sub>op</sub>): The openable window-to-floor ratio (WFR<sub>op</sub>) is the ratio of the total openable area to the total carpet area of dwelling units. The total openable area of a dwelling unit is the addition of openable area of all windows and venti-lators, opening directly to the external air, an open balcony, 'verandah', corridor or shaft; and the openable area of the doors opening directly into an open balcony.

Exclusions: Doors opening into corridors and external doors on ground floor (for e.g. groundfloor entrance doors or back-yard doors).

**Orientation Factor** ( $\omega$ ): It is a measure of the amount of direct and diffused solar radiation that is received on the vertical surface in a specific orientation. This factor accounts for and gives weightage to the fact that the solar radiation falling on different orientations of walls is not same.

**Projection Factor, Overhang:** Projection factor (overhang) is the ratio of the horizontal depth of the external shading projection to the sum of the height of a non-opaque component and the distance from the top of the same component to the bottom of the farthest point of the external shading projection, in consistent units (Figure 2).



**FIGURE 2** Projection factor, overhang

**Projection Factor, Side Fin:** Project factor (side fin) is the ratio of the horizontal depth of the external shading projection to the distance from a non-opaque component to the farthest point of the external shading projection, in consistent units (Figure 3).




Figure 3 Projection factor, side fin

**Residential Envelope Heat Transmittance (RETV):** RETV is the net heat gain rate (over the cooling period) through the building envelope of dwelling units (excluding roof) dividedby the area of the building envelope (excluding roof) of dwelling units. Its unit is  $W/m^2$ .

**Solar Heat Gain Coefficient** (SHGC)<sup>25</sup>: SHGC is the fraction of incident solar radiation admitted through non-opaque components, both directly transmitted, and absorbed and subsequently released inward through conduction, convection, and radiation (Figure 4).




FIGURE 4 Solar heat gain through a non-opaque component

Bureau of Indian Standards (BIS). 2016. National Building Code of India 2016. New Delhi: BIS.

**SHGC Equivalent**<sup>26</sup>: SHGC Equivalent is the SHGC for a non-opaque component with a permanent external shading projection. It is calculated by multiplying the External Shading Factor (ESF) with the SHGC of unshaded non-opaque component.

**U Value:** Thermal transmittance (U value) is the heat transmission in unit time through unit area of a material or construction and the boundary air films, induced by unit tempera-ture difference between the environments on either side. Unit of U value is W/m².K. TheU value for a wall/roof/glazing indicates its ability to transfer heat through conduction.

**Visible Light Transmittance (VLT):** VLT is the ratio of the total transmitted light to the total incident light. It is a measure of the transmitted light in the visible portion of the spectrum through a material.

**Window-to-Wall Ratio (WWR):** WWR is the ratio of the non-opaque building envelope components area to the envelope area (excluding roof) of dwelling units.

<sup>&</sup>lt;sup>26</sup> Bureau of Energy Efficiency (BEE). 2017. Energy Conservation Building Code 2017. New Delhi: BEE.

#### ANNEXURE 2 Climatic zone and classification of cities




FIGURE 5 Climate zone Map of Assam




FIGURE 6 District Map of Assam

TABLE 4 Details of latitude and longitude of Assam

S.No.	CITIES/TOWNS	LATITUDE	LONGITUDE
1	Barpeta	26° 19'N	91° 00'E
2	Bilasipara	26° 14'N	90° 14'E
3	Bongaigaon	26° 28'N	90° 34'E
4	Dhekiajuli	26° 42'N	92° 30'E
5	Dhubri	26° 02'N	89° 58'E
6	Dibrugarh	27° 29'N	94° 54'E
7	Digboi	27° 23'N	95° 38'E
8	Diphu	25° 50'N	93° 26'E
9	Gauripur	26° 05'N	89° 58'E
10	Goalpara	26° 10'N	90° 37'E
11	Golaghat	26° 31'N	93° 58'E
12	Guwahati	26° 11'N	91° 44'E
13	Haflong	25° 11'N	93° 02'E

ANINLAUNLO			ANNEXUKE Z
14	Hailakandi	24° 41'N	92° 34'E
15	Hojai	26° 00'N	92° 52'E
16	Jorhat	26° 45'N	94° 13'E
17	Karimganj	24° 52'N	92° 21'E
18	Kokrajhar	26° 24'N	90° 16'E
19	Lanka	25° 55'N	92° 57'E
20	Margherita	27° 17'N	95° 41'E
21	Mariani	26° 40'N	94° 20'E
22	Nagaon	26° 21'N	92° 41'E
23	Nalbari	26° 25'N	91° 26'E
24	North Lakhimpur	27° 14'N	94° 07'E
25	Rangia	26° 28'N	91° 38'E
26	Sibsagar	26° 59'N	94° 38'E
27	Silchar	24° 49'N	92° 48'E
28	Tezpur	26° 38'N	92° 48'E



# ANNEXURE 3 Calculation of openable window-to-floor area ratio (WFR<sub>op</sub>)

a) Calculate the openable area of each dwelling unit (DU) by adding the openable area of all windows and ventilators, opening directly to the external air, an open balcony, 'verandah', corridor or shaft; and the openable area of the doors opening directlyinto an open balcony (doors opening into the corridors and ground-floor externaldoors are not included).

$$A_{openable} = A_{openable} + A_{openable} + A_{openable} \dots (6)$$

In case exact openable area is not known, the following default values can be used:

**TABLE 5** Default openable area to opening area ratio

Type of window/door/ventilator	Percentage openable area
Casement	90%
Sliding (2 panes)	50%
Sliding (3 panes)	67%

Add openable areas of all dwelling units to get the total openable area.

$$A_{openable} = A_{openable_{DII}} + A_{openable_{DII}} + A_{openable_{DII}} + A_{openable_{DII}} + \dots$$
 (7)

b) Calculate the total carpet area by adding the carpet areas of all the dwelling units(DU). It excludes the areas covered by external walls, areas under services shafts, exclusive balcony or verandah area and exclusive open terrace area, but includes the areas covered by the internal partition walls of the dwelling unit.

$$A_{carpet} = A_{carpet_{DU1}} + A_{carpet_{DU2}} + A_{carpet_{DU3}} + \dots$$
 (8)

c) Calculate the openable window-to-floor area ratio (WFR<sub>op</sub>) by calculating the ratio of openable area to the carpet area.

$$WFR_{op} = \frac{A_{openable}}{A_{carpet}} \qquad ....(9)$$

#### ANNEXURE 4 Calculation of window-to-wall ratio (WWR)

a) Calculate the total non-opaque (transparent/translucent panels of windows, doors, ventilators, etc.) area of the building envelope for each dwelling unit.

$$A_{non-opaque} = A_{non-opaque} + A_{non-opaque} + A_{non-opaque} \dots (10)$$

Add non-opaque areas of all dwelling units to get the total non-opaque area of thebuilding block. Non-opaque components facing open corridors and enclosed shafts, as well as walls of common services such as lifts and staircase are to be excluded.

$$A_{non-opaque} = A_{non-opaque_{DU1}} + A_{non-opaque_{DU2}} + A_{non-opaque_{DU3}} + \dots$$
 ....(11)

b) Calculate the total envelope area (excluding roof) of dwelling units of the building block. For each wall of the building envelope, calculate the gross wall area (i.e., overall area of a wall including openings such as windows, ventilators, and doors, with measurement taken horizontally from outside surface to outside surface andmeasured vertically from the top of the floor to the top of the roof). Add the gross wall area of all walls to get the total envelope area (excluding roof) for the building. Walls facing open corridors and enclosed shafts, as well as walls of common services such as lifts and staircase are to be excluded.

$$A_{envelope} = A_{gross-wall} + A_{gross-wall} + A_{gross-wall} + \dots$$
 ....(12)

c) Calculate the window-to-wall ratio (WWR) by calculating the ratio of the total nonopaque area to the total envelope area.

$$WWR = \frac{A_{non-opaque}}{A_{envelope}} \qquad \dots (13)$$

# ANNEXURE 5 Calculation of thermal transmittance (U value) of roofand wall

a) Calculate the thermal resistance of each uniform material layer, which constitutes the building component, as follows:

$$R_i = \frac{t_i}{k} \qquad \dots (14)$$

where,

 $R_i$  is the thermal resistance of material layer i, m<sup>2</sup>.K/W

 $t_i$  is the thickness of material layer i, m

 $k_i$  is the thermal conductivity of material layer i, W/(m.K)

b) Find the total thermal resistance,  $R_T$ , as follows:

$$R_T = R_{si} + R_{se} + R_1 + R_2 + R_3 + \dots$$
 (15)

where.

 $R_{\tau}$  is the total thermal resistance, m<sup>2</sup>.K/W

 $R_{si}$  is the interior surface film thermal resistance,  $m^2.K/WR$  is the exterior surface film thermal resistance,  $m^2.K/WR$  is the thermal resistance of material layer 1,  $m^2.K/W$ 

 $R_2$  is the thermal resistance of material layer 2, m<sup>2</sup>.K/W

 $R_3$  is the thermal resistance of material layer 3, m<sup>2</sup>.K/W

Use these default values for calculation,

**TABLE 6** Values of surface film thermal resistance for U-value calculation

	Wall	Roof	
	All Climatic Zones	Composite Climate, Hot-Dry Climate, Warm-Humid Climate, and Temperate Climate	Cold Climate
$R_{si}(m^2.K/W)$	0.13	0.17	0.10
$R_{se}(m^2.K/W)$	0.04	0.04	0.04

SOURCE Adapted from Bureau of Energy Efficiency (BEE), 2009. Energy Conservation Building Code User Guide, New Delhi

The thermal conductivity of commonly used building materials is given in Table 7, which can be used to calculate the thermal resistance (R value).

c) Calculate the thermal transmittance (or the overall heat transfer coefficient or Uvalue) of a wall or roof assembly, as follows:

$$U = \frac{1}{R_T} \qquad \dots (16)$$

where,

U is the overall heat transfer coefficient,  $W/(m^2.K)$ 

Table 7 gives typical thermal properties of commonly used building and insulating mate-rials. This is not an all-inclusive list. In case, thermal conductivity values, measured using the appropriate IS codes, are available; those can also be used for calculations.

**TABLE 7** Thermal properties of building and insulating materials

Sl no.	Type of material	Density (kg/m³)	Thermal conductivity (W/m.K)	Specific heat capacity (kJ/kg.K)	Source
I. Buildi	ng materials				
1	Solid burnt clay brick	1920	0.980	0.80	(1)
2	Solid burnt clay brick	1760	0.850	NA	(1)
3	Solid burnt clay brick	1600	0.740	NA	(1)
4	Solid burnt clay brick	1440	0.620	NA	(1)
5	Resource efficient (hollow) brick	1520	0.631	0.65	(4)
6	Fly ash brick	1650	0.856	0.93	(2)
7	Solid concrete block 25/50	2427	1.396	0.20	(4)
8	Solid concrete block 30/60	2349	1.411	0.30	(4)
9	Aerated autoclaved concrete (AAC) block	642	0.184	1.24	(4)
10	Cement stabilized soil block (CSEB)	1700	1.026	1.03	(5)
11	Cement stabilized soil block (CSEB)	1800	1.201	1.07	(5)
12	Cement stabilized soil block (CSEB)	1900	1.303	1.07	(5)
13	Dense concrete	2410	1.740	0.88	(3)
14	Reinforced concrete cement (RCC)	2288	1.580	0.88	(3)
15	Brick tile	1892	0.798	0.88	(3)
16	Lime concrete	1646	0.730	0.88	(3)
17	Mud Phuska	1622	0.519	0.88	(3)
18	Cement mortar	1648	0.719	0.92	(3)
19	Cement plaster	1762	0.721	0.84	(3)
20	Gypsum plaster	1120	0.512	0.96	(3)
21	Cellular concrete	704	0.188	1.05	(3)
22	AC sheet	1520	0.245	0.84	(3)
Table 7 contd					

Bureau of Energy Efficiency (BEE)

DRAFT AENS 2021

23

ANNEXURE 5

Table 7 contd...

SI no.	Type of material	Density (kg/m³)	Thermal conductivity (W/m.K)	Specific heat capacity (kJ/kg.K)	Source
23	Gl sheet	7520	61.060	0.50	(3)
24	Timber	480	0.072	1.68	(3)
25	Timber	720	0.144	1.68	(3)
26	Plywood	640	0.174	1.76	(3)
27	Glass	2350	0.814	0.88	(3)
28	Tar felt (2.3 kg/m <sup>2</sup> )		0.479	0.88	(3)
II. Insu	llating materials				
1	Expanded polystyrene	16.0	0.038	1.34	(3)
2	Expanded polystyrene	24.0	0.035	1.34	(3)
3	Expanded polystyrene	34.0	0.035	1.34	(3)
4	Foam glass	127.0	0.056	0.75	(3)
5	Foam glass	160.0	0.055	0.75	(3)
6	Foam concrete	320.0	0.070	0.92	(3)
7	Foam concrete	400.0	0.084	0.92	(3)
8	Foam concrete	704.0	0.149	0.92	(3)
9	Cork slab	164.0	0.043	0.96	(3)
10	Cork slab	192.0	0.044	0.96	(3)
11	Cork slab	304.0	0.055	0.96	(3)
12	Rock wool (unbonded)	92.0	0.047	0.84	(3)
13	Rock wool (unbonded)	150.0	0.043	0.84	(3)
14	Mineral wool (unbonded)	73.5	0.030	0.92	(3)
15	Glass wool (unbonded)	69.0	0.043	0.92	(3)
16	Glass wool (unbonded)	189.0	0.040	0.92	(3)
17	Resin bonded mineral wool	48.0	0.042	1.00	(3)
18	Resin bonded mineral wool	64.0	0.038	1.00	(3)
19	Resin bonded mineral wool	99.0	0.036	1.00	(3)
20	Resin bonded mineral wool	16.0	0.040	1.00	(3)
21	Resin bonded mineral wool	24.0	0.036	1.00	(3)
22	Exfoliated vermiculite (loose)	264.0	0.069	0.88	(3)
23	Asbestos mill board	1397.0	0.249	0.84	(3)
24	Hard board	979.0	0.279	1.42	(3)
25	Straw board	310.0	0.057	1.30	(3)
26	Soft board	320.0	0.066	1.30	(3)
27	Soft board	249.0	0.047	1.30	(3)

Table 7 contd...

Table 7 contd

SI no.	Type of material	Density (kg/m³)	Thermal conductivity (W/m.K)	Specific heat capacity (kJ/kg.K)	Source
28	Wall board	262.0	0.047	1.26	(3)
29	Chip board	432.0	0.067	1.26	(3)
30	Chip board (perforated)	352.0	0.066	1.26	(3)
31	Particle board	750.0	0.098	1.30	(3)
32	Coconut pith insulation board	520.0	0.060	1.09	(3)
33	Jute fibre	329.0	0.067	1.09	(3)
34	Wood wool board (bonded with cement)	398.0	0.081	1.13	(3)
35	Wood wool board (bonded with cement)	674.0	0.108	1.13	(3)
36	Coir board	97.0	0.038	1.00	(3)
37	Saw dust	188.0	0.051	1.00	(3)
38	Rice husk	120.0	0.051	1.00	(3)
39	Jute felt	291.0	0.042	0.88	(3)
40	Closed cell flexible elastomeric foam - NBR	40–55	0.043	1.20	(3)

NA: Not available

#### **SOURCES**

- American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). 2009. 2009
   ASHRAE Handbook (Fundamentals). Atlanta. United States: ASHRAE
- Gourav K, et al. 2017. Studies into structural and thermal properties of building envelope mate- rials. Energy Procedia 122: 104–108
- (3) Bureau of Indian Standards (BIS). 1987. Handbook on Functional Requirements of Buildings (Other than Industrial Buildings) SP: 41 (S & T) -1987. New Delhi: BIS.
- (4) Thermo-Physical-Optical Property Database of Construction Materials, U.S.- India Joint Center for Building Energy Research and Development (CBERD) and Ministry of New and Renew- able Energy (MNRE). Available at http://www.carbse.org/wp-content/uploads/2017/10/Data- base-of-Construction-Materials\_Oct17.pdf (accessed on 1 May 2018).
- Balaji N C, et al. 2015. Influence of varying mix proportions on thermal performance of soil-ce-ment blocks. Building Simulation Applications (BSA). 2<sup>nd</sup> IBPSA Italy Conference, Building Simulation Application 2015 (BSA 2015). Available at http://www.ibpsa.org/proceedings/ BSA2015/9788860460745\_10.pdf (accessed on 1 May 2018).

In case, the construction has air layer, use values of thermal resistance of air layer given in Table 8 for U value calculation.

**TABLE 8** Values of unventilated air layer thermal resistance for U-value calculation

Thickness	Thermal resistance(m <sup>2</sup> .K/W)			
of Air Layer (mm)	Wall in All Climatic Zones	Roof in Composite Climate, Hot-Dry Climate, Warm-Humid Climate, and Temperate Climate	Roof in Cold Climate	
5	0.12	0.10	0.10	
7	0.12	0.12	0.12	
10	0.14	0.14	0.14	
15	0.16	0.16	0.16	
25	0.18	0.18	0.17	
50	0.18	0.20	0.17	
100	0.18	0.20	0.17	
300	0.18	0.21	0.17	

**SOURCE** Adapted from Bureau of Energy Efficiency (BEE), 2009. Energy Conservation Building Code User Guide. New Delhi



#### ANNEXURE 6 Orientation Factor

The orientation factor  $(\omega)$  is a measure of the amount of direct and diffused solar radiation that is received on the vertical surface in a specific orientation. This factor accounts for and gives weightage to the fact that the solar radiation falling on different orientationsof walls is not same. It has been defined for the latitudes  $\geq$ 23.5°N and latitudes  $\leq$ 23.5°N (Table 9). Table 9 should be read in conjunction with Figure 6.

		Orientation factor (ω)
Orientation	Latitudes ≥23.5°N	Latitudes <23.5°N
North (337.6°—22.5°)	0.550	0.659
North-east (22.6°—67.5°)	0.829	0.906
East (67.6°—112.5°)	1.155	1.155
South-east (112.6°—157.5°)	1.211	1.125
South (157.6°—202.5°)	1.089	0.966
South-west (202.6°—247.5°)	1.202	1.124
West (247.6°—292.5°)	1.143	1.156
North-west (292.6°—337.5°)	0.821	0.908





FIGURE 7 Primary orientations for determining the orientation factor ω

#### ANNEXURE 7 Calculation of Equivalent SHGC

SHGC Equivalent is the SHGC for a non-opaque component with a permanent external shading projection (overhang and side fins). It is calculated by multiplying the External Shading Factor (ESF) with the SHGC of unshaded non-opaque component. ESF values are defined based on the projection factor (PF). The procedure for calculation is given below:


- a) Calculate the projection factor (PF) for permanent external projection, including but not limited to overhangs, side fins, box frame, verandah, balcony, and fixed cano- pies, using the formula:
  - i. Projection factor, overhang: the ratio of the horizontal depth of the external shading projection  $(H_{overhang})$  to the sum of the height of a non-opaque component and the distance from the top of the same component to the bottom of the farthest point of the external shading projection  $(V_{overhang})$ , in consistent units.

$$PF_{overhang} = \frac{H_{overhang}}{V_{overhang}} \qquad ....(17)$$



ii. Projection factor, side/vertical fin: the ratio of the horizontal depth of the external shading projection to the distance from a non-opaque component to the farthestpoint of the external shading projection, in consistent units. In case of single side/vertical fin, it could be on the 'Right' or 'Left' or there could be side/vertical fins

on both the sides. A 'Right' side/vertical fin would be located on the right sideof the window while looking out from the building and similarly, a 'Left' side/vertical fin would be located on the left side of the window while looking outfrom the building.



- b) Select the ESF value for each shading element as:
  - i. Overhang (ESF<sub>overhang</sub>): Refer Table 10 and Table 11
  - ii. Side fin-right (ESF<sub>right</sub>): Refer Table 12 and Table 13
  - iii. Side fin-left (ESF  $_{\mbox{\scriptsize left}}$  ): Refer Table 14 and Table 15

DRAFT AENS 2021

**TABLE 10** External Shading Factor for Overhang (ESF  $_{\rm overhang}$  ) for LAT  $\geq$  23.5  $^{\circ}N$ 

	External Shading Factor for Overhang (ESF <sub>overhang</sub> ) for LAT $\geq 23.5^{\circ}$ N									
Orientation	North	North-east	East	South-east	South	South-west	West	North-west		
PF <sub>overhang</sub>	(337.6°—22.5°)	(22.6°—67.5°)	(67.6°—112.5°)	(112.6°—157.5°)	(157.6°—202.5°)	(202.6°—247.5°)	(247.6°—292.5°)	(292.6°-337.5°)		
< 0.10	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000		
0.10-0.19	0.955	0.930	0.922	0.906	0.881	0.905	0.922	0.930		
0.20-0.29	0.922	0.876	0.855	0.824	0.789	0.823	0.853	0.875		
0.30-0.39	0.897	0.834	0.796	0.755	0.719	0.753	0.794	0.834		
0.40-0.49	0.877	0.803	0.745	0.697	0.665	0.695	0.743	0.802		
0.50-0.59	0.860	0.779	0.702	0.652	0.626	0.650	0.700	0.778		
0.60-0.69	0.846	0.761	0.666	0.617	0.598	0.614	0.663	0.760		
0.70-0.79	0.834	0.747	0.635	0.590	0.580	0.587	0.632	0.746		
0.80-0.89	0.825	0.737	0.609	0.569	0.569	0.566	0.606	0.736		
0.90-0.99	0.817	0.729	0.587	0.554	0.563	0.551	0.585	0.728		
≥1	0.810	0.722	0.569	0.542	0.559	0.539	0.566	0.721		

 $\begin{tabular}{ll} \textbf{TABLE 11} External Shading Factor for Overhang (ESF_{overhang}) for LAT \!\!<\!\! 23.5^\circ\!N \\ \end{tabular}$ 

			_							
	External Shading Factor for Overhang (ESF <sub>overhang</sub> ) for LAT < 23.5°N									
Orientation	North	North-east	East	South-east	South	South-west	West	North-west		
PF <sub>overhang</sub>	(337.6°—22.5°)	(22.6°—67.5°)	(67.6°—112.5°)	(112.6°—157.5°)	(157.6°—202.5°)	(202.6°—247.5°)	(247.6°—292.5°)	(292.6°–337.5°)		
< 0.10	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000		
0.10-0.19	0.931	0.924	0.922	0.910	0.896	0.910	0.922	0.924		
0.20-0.29	0.888	0.864	0.855	0.834	0.816	0.834	0.854	0.864		
0.30-0.39	0.860	0.818	0.797	0.771	0.754	0.771	0.796	0.818		
0.40-0.49	0.838	0.782	0.747	0.721	0.708	0.720	0.746	0.782		
0.50-0.59	0.820	0.755	0.705	0.682	0.675	0.681	0.705	0.755		
0.60-0.69	0.806	0.734	0.670	0.651	0.653	0.651	0.670	0.734		
0.70-0.79	0.793	0.718	0.641	0.628	0.638	0.627	0.640	0.717		
0.80-0.89	0.783	0.706	0.616	0.610	0.628	0.609	0.615	0.705		
0.90-0.99	0.775	0.696	0.596	0.596	0.621	0.596	0.595	0.695		
≥1	0.768	0.688	0.579	0.585	0.616	0.585	0.578	0.688		



DRAFT AENS 2021

TABLE 12 External Shading Factor for Side Fin-Right (ESF  $_{\rm right}$  ) for LAT  $\geq$  23.5  $^{\circ}N$ 

	External Shading Factor for Side Fin-Right (ESF $_{right}$ ) for LAT $\geq 23.5^{\circ}N$								
Orientation	North	North-east	East	South-east	South	South-west	West	North-west	
PF <sub>right</sub>	(337.6°—22.5°)	(22.6°—67.5°)	(67.6°—112.5°)	(112.6°—157.5°)	$(157.6^{\circ}-202.5^{\circ})$	(202.6°—247.5°)	(247.6°—292.5°)	(292.6°-337.5°)	
< 0.10	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	
0.10-0.19	0.968	0.942	0.972	0.982	0.961	0.965	0.988	0.985	
0.20-0.29	0.943	0.894	0.949	0.968	0.933	0.934	0.977	0.972	
0.30-0.39	0.924	0.855	0.931	0.957	0.912	0.907	0.968	0.961	
0.40-0.49	0.911	0.824	0.917	0.950	0.898	0.884	0.960	0.953	
0.50-0.59	0.899	0.798	0.905	0.944	0.887	0.865	0.954	0.945	
0.60-0.69	0.890	0.777	0.895	0.939	0.880	0.849	0.948	0.939	
0.70-0.79	0.883	0.762	0.887	0.936	0.875	0.837	0.943	0.934	
0.80-0.89	0.877	0.750	0.881	0.933	0.872	0.827	0.939	0.930	
0.90-0.99	0.871	0.739	0.875	0.930	0.868	0.819	0.935	0.926	
≥1	0.865	0.731	0.870	0.927	0.865	0.812	0.932	0.922	



ANNEXURE 7

 $\begin{tabular}{ll} \textbf{TABLE 13} External Shading Factor for Side Fin-Right (ESF_{right}) for LAT \!\!<\!\! 23.5^{\circ}N \\ \end{tabular}$ 

	External Shading Factor for Side Fin-Right (ESF <sub>right</sub> ) for LAT < 23.5°N									
<b>Orientation PF</b>	North (337.6°—22.5°)	North-east (22.6°—67.5°)	East (67.6°—112.5°)	South-east (112.6°—157.5°)	South (157.6°—202.5°)	South-west (202.6°—247.5°)	West (247.6°—292.5°)	North-west (292.6°–337.5°)		
PF <sub>right</sub>		, ,		,	,		,	,		
< 0.10	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000		
0.10-0.19	0.962	0.948	0.975	0.982	0.962	0.959	0.984	0.984		
0.20-0.29	0.934	0.904	0.954	0.968	0.932	0.924	0.970	0.970		
0.30-0.39	0.913	0.868	0.937	0.957	0.911	0.894	0.958	0.959		
0.40-0.49	0.900	0.840	0.924	0.949	0.896	0.870	0.949	0.950		
0.50-0.59	0.888	0.816	0.912	0.942	0.885	0.849	0.940	0.942		
0.60-0.69	0.879	0.797	0.903	0.936	0.877	0.832	0.933	0.936		
0.70-0.79	0.872	0.782	0.896	0.932	0.872	0.820	0.927	0.931		
0.80-0.89	0.866	0.770	0.889	0.929	0.867	0.810	0.922	0.927		
0.90-0.99	0.860	0.760	0.884	0.925	0.863	0.801	0.917	0.923		
≥1	0.855	0.752	0.878	0.922	0.859	0.794	0.913	0.919		



Bureau of Energy Efficiency (BEE)

TABLE 14 External Shading Factor for Side Fin-Left (ESF  $_{left}$  ) for LAT  $\geq$  23.5  $^{\circ}N$ 

	<b>External Shading</b>	Factor for Side Fin-Le	eft (ESF <sub>left</sub> ) for LAT $\geq 2$	3.5°N				
Orientation PF <sub>left</sub>	North (337.6°—22.5°)	North-east (22.6°—67.5°)	East (67.6°—112.5°)	South-east (112.6°—157.5°)	South (157.6°—202.5°)	South-west (202.6°—247.5°)	West (247.6°—292.5°)	North-west (292.6°–337.5°)
<0.10	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000
0.10-0.19	0.968	0.985	0.988	0.965	0.961	0.982	0.972	0.942
0.20-0.29	0.943	0.972	0.977	0.933	0.932	0.967	0.949	0.895
0.30-0.39	0.925	0.961	0.968	0.906	0.911	0.957	0.931	0.857
0.40-0.49	0.912	0.953	0.961	0.883	0.897	0.949	0.916	0.826
0.50-0.59	0.900	0.946	0.954	0.863	0.886	0.943	0.904	0.801
0.60-0.69	0.890	0.939	0.948	0.846	0.879	0.938	0.895	0.781
0.70-0.79	0.884	0.935	0.944	0.834	0.874	0.935	0.887	0.766
0.80-0.89	0.877	0.931	0.940	0.824	0.871	0.932	0.881	0.754
0.90-0.99	0.871	0.927	0.936	0.815	0.867	0.929	0.875	0.744
≥1	0.866	0.923	0.932	0.808	0.864	0.927	0.870	0.736



 $\textbf{TABLE 15} \ External \ Shading \ Factor \ for \ Side \ Fin-Left \ (ESF_{left}) \ for \ LAT < 23.5^{\circ}N$ 

	External Shading Factor for Side Fin-Left (ESF <sub>left</sub> ) for LAT < 23.5°N									
Orientation	North	North-east	East	South-east	South	South-west	West	North-west		
PF <sub>left</sub>	(337.6°—22.5°)	(22.6°—67.5°)	(67.6°—112.5°)	(112.6°—157.5°)	$(157.6^{\circ}-202.5^{\circ})$	(202.6°—247.5°)	(247.6°—292.5°)	(292.6°–337.5°)		
< 0.10	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000		
0.10-0.19	0.962	0.984	0.984	0.959	0.962	0.982	0.975	0.948		
0.20-0.29	0.933	0.970	0.970	0.924	0.932	0.968	0.954	0.904		
0.30-0.39	0.912	0.959	0.958	0.895	0.911	0.956	0.937	0.868		
0.40-0.49	0.899	0.950	0.949	0.870	0.896	0.948	0.924	0.840		
0.50-0.59	0.887	0.942	0.941	0.849	0.885	0.942	0.913	0.816		
0.60-0.69	0.878	0.935	0.933	0.833	0.877	0.936	0.903	0.797		
0.70-0.79	0.871	0.931	0.928	0.820	0.871	0.932	0.896	0.783		
0.80-0.89	0.865	0.926	0.923	0.810	0.867	0.928	0.890	0.771		
0.90-0.99	0.859	0.922	0.918	0.801	0.863	0.925	0.884	0.761		
≥1	0.854	0.919	0.913	0.794	0.859	0.922	0.879	0.752		

c) Calculate the total external shading factor (ESF<sub>total</sub>) using the formula:

$$ESF_{total} = ESF_{overhame} \times ESF_{sidefin}$$
 ....(20)

where,

$$ESF_{sidefin} = 1 - \left[ \left( 1 - ESF_{right} \right) + \left( 1 - ESF_{left} \right) \right]$$
(21)

d) Calculate the equivalent SHGC of the fenestration (SHGC<sub>eq</sub>) by multiplying the SHGC of the unshaded fenestration product (SHGC<sub>Unshaded</sub>) with the total external shading factor (ESF<sub>total</sub>), using the formula:


$$SHGC_{eq} = SHGC_{Unshaded} \times ESF_{total}$$
 ....(22)



# ANNEXURE 8 Examples of Code Compliance

**Example 1:** A 7-storey housing project in Rajkot is trying to comply with the residen-tial code. There are 11 identical residential towers in this project. The carpet area of eachdwelling unit (DU) is 26.6 m<sup>2</sup>.

There are three windows (W1, W2, W3) and one door (D) in each DU exposed to ambient. The windows are either fully glazed or partially glazed (glass and PVC panels) and are casement windows. The door is opaque with PVC panel. Each DU has two ventilators (V)in the bath and toilet, which face a ventilation shaft. The details of the exposed door, windows, and ventilators are given below.



**FIGURE 8** Layout plan of the project (Example 1)




FIGURE 9 Plan of a typical DU (Example 1)

 TABLE 16
 Details of exposed doors, windows, and ventilators (Example 1)

Opening window/door/ ventilator	Opening width (m)	Opening height (m)	Opening area (m²)	Width of glass in Opening (m)	Height of glass in Opening (m)	Glass area in opening (m²)	Opaque area (m²)
W1	1.20	1.60	1.92	1.20	0.53	0.64	1.28
W2	0.80	1.30	1.04	0.80	0.43	0.35	0.69
W3	0.80	1.60	1.28	0.80	1.60	1.28	0.00
D	0.75	2.50	1.87	0.00	0.00	0.00	1.87
V (2 nos)	0.65	0.40	0.26	0.65	0.40	0.26	0.00

Material details are as follows:

**TABLE 17** Details of construction material (Example 1)

Wall	200 mm AAC blocks with plaster on both sides. U-value 0.78 W/m <sup>2</sup> .K
Roof	150 mm RCC with 40 mm polyurethane foam (PUF) insulation
Glass in windows	Single clear glass with SHGC 0.80, VLT 85%, and U-value 5.80 W/m <sup>2</sup> .K
PVC panel	4 mm thick PVC panel used in doors and windows. U-value 5.23 W/m <sup>2</sup> .K


Does this project comply with the code?

#### **Compliance check:**

Each of the 11 residential towers will need to comply with the code for the building project to be compliant. Though the towers are identical, their orientations differ.

The longer walls of Towers A-E face north-south, i.e., 0° and 180°. Towers F-I face 345° and 165°. Towers J and K face east-west, i.e., 90° and 270°. As per Table 8 in Annexure 6, Towers A-E and F-I can be considered having the same orientation. Thus, for this project, compliance may be shown for one of Towers A-I and one of Towers J and K.

In this example, compliance of Tower C, as marked in Figure 9, is being shown.



**FIGURE 10** Building for compliance check on the layout of project (Example 1)

The longer sides of this tower face north-south. It has 112 dwelling units (DUs), 16 DUs oneach floor. Half of the DUs face north and the rest face south.

**TABLE 18** Envelope areas of the building (Example 1)

Orientation	Total wall length (m), exposed to ambient	Total wall height (m), exposed to ambient	Envelope area (m²)
North	51.58	21.06	1086.27
South	51.58	21.06	1086.27
East	31.00	21.06	652.86
West	31.00	21.06	652.86
Envelope area (m <sup>2</sup> ), excluding roof			3478.26

## Step 1: Openable window-to-floor area ratio (WFR)

### 1.1: Calculation of total openable area (A<sub>openable</sub>)

Each flat consists of three windows, one door opening to the balcony, and two ventilators. As all of them are casement openings, 90% of the opening area is considered openable.

**TABLE 19** Openable area calculation (Example 1)

Opening name	Opening area (m²)	Openable area (m²)
W1	1.92	1.73
W2	1.04	0.94
W3	1.28	1.15
D (opening into balcony)	1.87	1.69
V (2 nos)	0.52	0.47
Openable area for each flat		5.97
Openable area for 112 flats (A <sub>open</sub>	<sub>aable</sub> )	668.81

# 1.2: Calculation of total carpet area (A<sub>carpet</sub>)

$$A_{carpet} = no. \ of \ DUs \ \mathbf{x} \ carpet \ area \ of \ 1 \ DU = 112 \ \mathbf{x} \ 26.6 = 2979.20 \ m^2$$

## 1.3: Calculate the openable window-to-floor area ratio (WFR $_{\rm op}$

$$WFR_{op} = \frac{A_{openable}}{A_{carpet}} = \frac{668.81}{2979.20} = 22.45\%$$

Rajkot is in the composite climate. As per Table 1, the minimum  $WFR_{op}$  for this climate is 12.5%. Thus, this project complies with this requirement.

### Step 2: Visible Light Transmittance (VLT)

#### 2.1: Calculation of window-to-wall ratio (WWR)

There are three windows and one door in each DU exposed to ambient. The windows areeither fully glazed or partially glazed (glass and PVC panels). The door is opaque with PVC panel.

TABLE 20	Calculation 6	of	window-to-wall	ratio	(Example 1	)

Orientation	Opening name	Opening area (m²)	Non-opaque (glass) area in opening (m²)	No. of openings	Total opening area (m²)	Total non-opaque (glass) area (m²)
North	W1	1.92	0.64	56	107.52	35.62
North	W2	1.04	0.35	56	58.24	19.26
North	W3	1.28	1.28	56	71.68	71.68
North	D	1.88	0.00	56	105.00	0.00
South	W1	1.92	0.64	56	107.52	35.62
South	W2	1.04	0.35	56	58.24	19.26
South	W3	1.28	1.28	56	71.68	71.68
South	D	1.88	0.00	56	105.00	0.00
Total					684.88	253.16

$$WWR = \frac{A_{non-opaque}}{A_{envelope}} = \frac{253.12}{3478.26} = 0.073$$

As per Table 2, for WWR of 0.073 (range 0-0.30), the minimum required VLT is 27%. The glass used in this project has a VLT of 85% (as per certified specification for the product). Thus, this project complies with this requirement. Also, it complies with the recom- mended value.

# Step 3: Thermal transmittance of roof ( $U_{roof}$ )

3.1: Calculation of thermal transmittance of roof  $(U_{root})$ 

The roof of this building comprises the following material layers.

**TABLE 21** Roof construction details (Example 1)

Material layer	Thickness, t (m)	Thermal conductivity, k (W/m.K)	Thermal resistanceof material, R= t/k (m².K/W)
China mosaic tile	0.007	1.500	0.005
Concrete (laid to slope)	0.050	1.740	0.029
Polyurethane foam (PUF)	0.040	0.023	1.739
Cement screed	0.020	0.720	0.028
RCC slab	0.150	1.580	0.095
Internal plaster	0.015	0.720	0.021
Sum of all material thermal resistance			1.917

Total thermal resistance,

$$R_T = R_{si} + R_{se} + R_1 + R_2 + R_3 + \dots$$
  
= 0.17 + 0.04 + 1.917 = 2.127 m<sup>2</sup>.K / W

Thermal transmittance of roof,

$$U_{roof} = \frac{1}{R_T} = 0.47 \text{ W} / \text{m}^2.\text{K}$$

This is less than the maximum  $U_{roof}$  value of 1.2 W/m<sup>2</sup>.K. Hence it complies with this requirement.

## Step 4: RETV of the building envelope (except roof)

#### 41 : Calculation of envelope area, in every orientation

**TABLE 22** Calculation of envelope area for each orientation (Example 1)

Orientation		Area (m²)	U value (W/m².K)
	Non-opaque (glass) area	126.56	5.80
North	Opaque area 1 (AAC wall)	743.83	0.78
	Opaque area 2 (PVC panel in doors and windows)	215.88	5.23
	Non-opaque (glass) area	126.56	5.80
South	Opaque area 1 (AAC wall)	743.83	0.78
	Opaque area 2 (PVC panel in doors and windows)	215.88	5.23
	Non-opaque (glass) area	0.00	
East	Opaque area 1 (AAC wall)	652.86	0.78
	Opaque area 2 (PVC panel in doors and windows)	0.00	
	Non-opaque (glass) area	0.00	
West	Opaque area 1 (AAC wall)	652.86	0.78
	Opaque area 2 (PVC panel in doors and windows)	0.00	
Total Envelope A	rea, A <sub>envelope</sub>	3478.26	

(The U values of AAC block and PVC sheet are calculated the same way as that shown for the roof. The thermal conductivity of AAC block is 0.184~W/m.K and that of PVC is 0.19~W/m.K.)

### ${\tt 42:} Calculation\ of\ equivalent\ SHGC\ of\ non-opaque\ openings, for\ each\ orientation$

**TABLE 23** Calculation of equivalent SHGC of non-opaque openings for each orientation (Example 1)

Orientation	Name	Width of Glass (m)	Height of Glass (m)	No.of Windows	Glass Area (m²)	H <sub>overhang</sub> (m)	V <sub>overhang</sub> (m)	PFoverhang	H <sub>right</sub> (m)	V <sub>right</sub> (m)	PF <sub>right</sub>	H <sub>left</sub> (m)	V <sub>left</sub> (m)	PF <sub>left</sub>	ESF <sub>overhang</sub>	ESF <sub>right</sub>	ESF <sub>left</sub>	ESF <sub>total</sub>	SHGC
North	W1	1.20	0.53	56	35.62	0.40	0.53	0.75	0.40	1.20	0.33	0.40	1.20	0.33	0.793	0.913	0.912	0.654	0.523
North	W2-1	0.80	0.43	28	9.63	1.10	0.43	2.56	1.10	1.75	0.63	1.10	0.80	1.38	0.768	0.879	0.854	0.563	0.450
North	W2-2	0.80	0.43	28	9.63	1.10	0.43	2.56	1.10	0.80	1.38	1.10	1.75	0.63	0.768	0.855	0.878	0.563	0.450
North	W3-1	0.80	1.60	28	35.84	0.47	1.60	0.29	3.10	0.80	3.88	0.47	0.80	0.59	0.888	0.855	0.887	0.659	0.527
North	W3-2	0.80	1.60	28	35.84	0.47	1.60	0.29	0.47	0.80	0.59	3.10	0.80	3.88	0.888	0.888	0.854	0.659	0.527
South	W1	1.20	0.53	56	35.62	0.40	0.53	0.75	0.40	1.20	0.33	0.40	1.20	0.33	0.638	0.911	0.911	0.524	0.420
South	W2-1	0.80	0.43	28	9.63	1.10	0.43	2.56	1.10	1.75	0.63	1.10	0.80	1.38	0.616	0.877	0.859	0.453	0.363
South	W2-2	0.80	0.43	28	9.63	1.10	0.43	2.56	1.10	0.80	1.38	1.10	1.75	0.63	0.616	0.859	0.877	0.453	0.363
South	W3-2	0.80	1.60	28	35.84	0.47	1.60	0.29	3.10	0.80	3.88	0.47	0.80	0.59	0.816	0.859	0.885	0.607	0.486
South	W3	0.80	1.60	28	35.84	0.47	1.60	0.29	0.47	0.80	0.59	3.10	0.80	3.88	0.816	0.885	0.859	0.607	0.486



#### 43 : Calculation of RETV

Rajkot is in the composite climate zone. Thus, the RETV equation, with applicable coefficients, is:

$$RETV = \frac{1}{A_{envelope}} \times \begin{bmatrix} \left\{ 6.06 \times \sum_{i=1}^{n} \left( A_{opaque_i} \times U_{opaque_i} \times \omega_i \right) \right\} & Term-II \\ + \left\{ 1.85 \times \sum_{i=1}^{n} \left( A_{non-opaque_i} \times U_{non-opaque_i} \times \omega_i \right) \right\} & Term-III \\ + \left\{ 68.99 \times \sum_{i=1}^{n} \left( A_{non-opaque_i} \times SHGC_{eq_i} \times \omega_i \right) \right\} & Term-IIII \end{bmatrix}$$

Calculation for the 3 terms are shown in table below:

**Table 24** Calculation of 3 terms of RETV formula

Calculation for	Term-I				
Orientation	Component	(a) Area (m²)	(b) U value (W/m².K)	(c) Orientation factor*,	(a) x (b) x (c)
North	Opaque area 1 (AAC wall)	743.83	0.78	0.659	382.34
North	Opaque area 2 (PVC panel in doors and windows)	215.88	5.23	0.659	744.05
South	Opaque area 1 (AAC wall)	743.83	0.78	0.966	560.46
South	Opaque area 2 (PVC panel in doors and windows)	215.88	5.23	0.966	1090.66
East	Opaque area 1 (AAC wall)	652.86	0.78	1.155	588.16
West	Opaque area 1 (AAC wall)	652.86	0.78	1.156	588.67
				Term-I Total	3954.35
<b>Calculation for</b>	Term-II				
Orientation	Component	(a) Area (m²)	(b) U value (W/m².K)	(c) Orientation factor*, ω	(a) x (b) x (c)
North	Non-opaque (glass) area	126.56	5.80	0.659	483.74
South	Non-opaque (glass) area	126.56	5.80	0.966	709.09
				Term-II Total	1192.83
Calculation for	Term-III				
Orientation	Component	(a) Area (m²)	(b) Equivalent SHGC #	(c) Orientation factor*, ω	(a) x (b) x (c)
North	W1	35.62	0.523	0.659	12.28
North	W2-1	9.63	0.450	0.659	2.86
North	W2-2	9.63	0.450	0.659	2.86

an I	11	24			1
Tal	าเอ	1.4	CO	ntı	1

North	W3-1	35.84	0.527	0.659	12.45
North	W3-2	35.84	0.527	0.659	12.45
South	W1	35.62	0.420	0.966	14.45
South	W2-1	9.63	0.363	0.966	3.38
South	W2-2	9.63	0.363	0.966	3.38
South	W3-1	35.84	0.486	0.966	16.83
South	W3-2	35.84	0.486	0.966	16.83
				Term-III Total	97.74

<sup>\*</sup> Orientation factor is taken from Annexure 6; For Latitude < 23.5 N and the specific orientation. E.g. for North orientation it is 0.659

Substitute the values of 3 terms and envelope area in the RETV formula:

$$RETV = \frac{1}{3478.26} \times \left[ \{6.06 \times 3954.35\} + \{1.85 \times 1192.83\} + \{68.99 \times 97.74\} \right]$$

$$RETV = 9.46 \frac{W}{m^2}$$

This is less than the maximum RETV of 15 W/m<sup>2</sup>. Hence it complies with this requirement.

#### The building complies with all four requirements and hence complies with the code.

**Example 2:** The same project given in Example 1 is built in Shimla. All specifications of the project remain the same except that all windows (W1, W2, W3) are fully glazed and sliding. The details of the exposed door, windows, and ventilators for this project are given below.

TABLE 25 Details of exposed door, windows, and ventilators (Example 2)

Opening window/door/ ventilator	Opening width (m)	Opening height (m)	Opening area (m²)	Width of glass in opening (m)	Height of glass in opening (m)	Glass area in opening (m²)	Opaque area (m²)
W1	1.20	1.60	1.92	1.20	1.60	1.92	0.00
W2	0.80	1.30	1.04	0.80	1.30	1.04	0.00
W3	0.80	1.60	1.28	0.80	1.60	1.28	0.00
D	0.75	2.50	1.87	0.00	0.00	0.00	1.87
V (2 nos)	0.65	0.40	0.26	0.65	0.40	0.26	0.00

<sup>#</sup> Refer to step 4.2 for details.

#### Material details are as follows:

**TABLE 26** Details of construction material (Example 2)

Wall	200 mm AAC blocks with plaster on both sides. U-value 0.78 W/m <sup>2</sup> .K
Roof	$150\ mm\ RCC\ with\ 40\ mm\ polyurethane\ foam\ (PUF)\ insulation.\ U-value\ 0.47\ W/m^2.K$
Glass in windows	Single clear glass with SHGC 0.80, VLT 85%, and U-value 5.80 W/m <sup>2</sup> .K
PVC panel	4 mm thick PVC panel used in doors. U-value 5.23 W/m <sup>2</sup> .K

Does this project comply with the code?

#### **Compliance check:**

Each of the 11 residential towers will need to comply with the code for the building project to be compliant. The compliance of one of the towers is being shown.

The longer sides of this tower face north-south. It has 112 dwelling units (DUs), 16 DUs oneach floor. Half of the DUs face north and the rest face south.

**TABLE 27** Envelope areas of the building (Example 2)

Orientation	Total wall length (m), exposed to ambient	Total wall height (m), exposed to ambient	Gross wall area (m²)
North	51.58	21.06	1086.27
South	51.58	21.06	1086.27
East	31.00	21.06	652.86
West	31.00	21.06	652.86
Envelope area (m²), excludi	ng roof		3478.26

## Step 1: Openable window-to-floor area ratio (WFR

### 1.1 : Calculation of total openable area $(A_{openable})$

Each flat consists of three windows, one door opening to the balcony, and two ventilators. As all the windows are sliding windows, 50% of the window opening area is considered openable. The door and ventilators are 90% openable.

**TABLE 28** Calculation of openable areas (Example 2)

Opening name	Opening area (m²)	Openable area (m²)	Remarks
W1	1.92	0.96	
W2	1.04	0.52	50% openable (Table 5)
W3	1.28	0.64	
D	1.87	1.69	000/
V (2 nos)	0.52	0.47	90% openable (Table 5)
Openable area for each	h flat	4.28	
Openable area for 112	flats $(A_{openable})$	478.86	

### 1.2 : Calculation of total carpet area $(A_{carpet})$

$$A_{carpet}$$
 = no. of DUs x built-up area of 1 DU = 112 x 26.6 = 2979.20 m<sup>2</sup>

### 13: Calculate the openable window to floor area ratio (WFR<sub>on</sub>)

$$WFR_{op} = \frac{A_{openable}}{A_{carpet}} = \frac{478.86}{2979.20} = 16.1\%$$

Shimla is in the cold climate zone. As per Table 1, the minimum WFR $_{op}$  for this climate is 8.33%. Thus, this project complies with this requirement.

### Step 2: Visible Light Transmittance (VLT)

#### 2.1: Calculation of window-to-wall ratio (WWR)

There are three windows and one door in each DU exposed to ambient. The windows arefully glazed. The door is opaque with PVC panel.

Orientation	Opening name	Opening area (m²)	Non-opaque areain opening (m²)	No. of openings	Total opening area (m <sup>2</sup> )	Total non-opaque area (m²)
North	W1	1.92	1.92	56	107.52	107.52
North	W2	1.04	1.04	56	58.24	58.24
North	W3	1.28	1.28	56	71.68	71.68
North	D	1.88	0.00	56	105.00	0.00
South	W1	1.92	1.92	56	107.52	107.52
South	W2	1.04	1.04	56	58.24	58.24
South	W3	1.28	1.28	56	71.68	71.68
South	D	1.88	0.00	56	105.00	0.00
Total					684.88	474.88

**TABLE 29** Calculation of window-to-wall ratio (Example 2)

$$WWR = \frac{A_{non-opaque}}{A_{envelope}} = \frac{474.88}{3478.26} = 0.136$$

As per Table 2, for WWR of 0.136 (range 0—0.30), the minimum required VLT is 27%. The glass used in this project has a VLT of 85% (as per certified specification for the product). Thus, this project complies with this requirement. Also, it complies with the recommended value.

## Step 3: Thermal transmittance of roof $(U_{roof})$

### 3.1: Calculation of thermal transmittance of $roof(U_{roof})$

The roof of this building is the same as that of Example 1, i.e.,  $U_{roof}$  is 0.47 W/m<sup>2</sup>.K. This isless than the maximum  $U_{roof}$  value of 1.2 W/m<sup>2</sup>.K. Hence it complies with this requirement.

## Step 4: Thermal transmittance of building envelope (except roof) forcold climatic

zone 
$$(U_{envelope, cold})$$

Shimla is in the cold climate zone. Hence, the thermal transmittance of the building enve-lope (except roof) will be calculated.

### 41 : Calculation of thermal transmittance of building envelope ( $U_{envelope\ cold}$ )

In this case, the U values of the wall (i.e., AAC block with 15 mm plaster on both sides), theopaque door component (i.e., PVC sheet), and the non-opaque components (glass used in windows) need to be combined as per the relative areas of each.

$$U_{\it envelope, cold}$$

 $= \underbrace{\left(AAC\ block\ wall\ area \times U\ value\ of\ AAC\right) + \left(Opaque\ door\ area \times U\ value\ of\ PVC\right) + \left(Non-opaque\ area \times U\ value\ of\ glass\right)}_{AAC\ block\ wall\ area} + Opaque\ door\ area + Non-opaque\ area}$ 

$$= \frac{(2793.38 \times 0.78) + (210.00 \times 5.23) + (474.88 \times 5.80)}{2793.38 + 210.00 + 474.88} = 1.73 \text{ W/m}^2.\text{K}$$

#### Note:

- Net AAC block area = Envelope area Total opening area
- Opaque door area= Total opening area Total non-opaque area
- U values of the AAC block and the PVC sheet are calculated the same way as that shown for the roof. The thermal conductivity of AAC block is 0.184 W/m.K and that of PVC is 0.19 W/m.K
- U value of the glass used is given as 5.80 W/m<sup>2</sup>.K (as per certified specification for the product)

This is less than the maximum  $U_{envelope cold}$  value of 1.8 W/m<sup>2</sup>.K. Hence it complies with this requirement.

The building complies with all four requirements and hence complies with the code.



## ANNEXURE 9 Guidelines for Design for Natural Ventilation

This annexure provides a simple and illustrative interpretation of provisions for the location of windows in a room and its impact on natural ventilation. A detailed designguideline for natural ventilation is available in the NBC 2016<sup>27</sup> (Volume II, Part 8 Building Services, Section 1 Lighting and Natural Ventilation).

The code gives the following provision for minimum WFR<sub>op</sub> values for natural ventilation(Table 1, Section 3.1):

TABLE 30 Minimum requirement of window-to-floor area ratio, WFR<sub>op</sub>

Climatic zone	Minimum WFR <sub>op</sub> (%)	
Warm-Humid	16.66	
Cold	8.33	

SOURCE Bureau of Indian Standards (BIS), 2016. National Building Code of India 2016. New Delhi: BIS.

Openable window-to-floor area ratio (WFR<sub>op</sub>) indicates the potential of using external air for ventilation. The openable area allows external air, when the ambient temperature is cooler than the inside air, into the internal spaces, which helps in ventilation, improve- ment in thermal comfort, and consequent reduction in cooling energy.

This openable area can be distributed on the external wall in a number of ways. Roomsmay have openings on only one external wall or multiple external walls (usually two external walls). Some guidelines for design of these openings are given below. It is to benoted that internal doors cannot be relied for enhancing ventilation and are assumed tobe closed.<sup>28</sup>

1. Distribution of the openable area on the external walls of a dwelling unit must be done to maximize cross-ventilation, i.e., the air inlet and outlet openings should be separate and positioned on different walls in a way that optimizes the air flow paththrough the space. This can be done by placing openings on adjacent walls or on opposite walls, where possible (Figure 10).

Bureau of Indian Standards (BIS). 2016. National Building Code of India 2016. New Delhi: BIS.

Heat exchange during night-time in hot/warm climates has greater value for thermal comfort. At this time, it is generally seen now that people keep the doors of their private rooms, i.e., the internal doors, closed.




Figure 11 Openings on adjacent or opposite external walls for cross ventilation (Guideline)

2. In rooms that have openable area on only one external wall, cross ventilation can beachieved by having an opening at a higher level on one of the internal walls (Figure 11). This will enhance cross ventilation through the habitable space. This principle can be extended from room to room, for instance, from a bedroom into a living room which is cross-ventilated, thus enhancing cross ventilation through the entiredwelling unit.




Figure 12 Openings on external wall and internal wall for cross ventilation (Guideline)

3. In rooms with only one external wall, and where cross ventilation is not possible (seepoint 2, above), provision of multiple windows on the external wall is preferred to

that of a single window (Figure 12). The farther apart these windows are placed on the wall, the better is the effect of air movement across the room.





Figure 13 Two windows on single external wall (Guideline)

4. Adding a ventilator above the windows on the external wall helps increase the rateof convective heat exchange (Figure 13). This is especially helpful in cases where windows are available on only one external wall and there is no means of cross ventilation.




**Figure 14** Adding ventilators above windows improves ventilation especially when onlysingle external wall is available for openings (Guideline)

The following illustrative diagrams recommend good design strategies to help achievebetter air exchange and increase the rate of heat loss through the buildings.


#### **Single-sided ventilation**

Case 1: Room with only one opening on the external wall




Addition of ventilator at an upper level increases the rate of convective heat exchange with the outside air.

Case 2: Room with multiple openings on the external wall




#### Cross ventilation

Case 1: Room with openings on both the external wall and another internal orexternal wall.



#### Comparison



For the same ratio of area of openings to floor area of a room, the thermal heat exchange increases as the number of openings increases on the wall.<sup>29</sup> it is thus recommended tohave openable ventilators to aid better ventilation.

This conclusion is generally valid for hot-dry, warm-humid climates. For cold regions, this may vary.

### Annexure 10 Cool Roof and Roof Gardens

A cool roof is one that reflects most of the incident solar radiation and efficiently emits some of the absorbed radiation back into the atmosphere, instead of conducting it to thebuilding below.<sup>30</sup> The term specifically refers to the outer layer or exterior surface of the roof, which acts as the key reflective surface.<sup>31</sup> A cool roof minimizes the solar heat gain of a building by first reflecting a considerable amount of incoming radiation and thenby quickly re-emitting the absorbed portion. Cool roof encompasses an extensive arrayof applications including roof coatings, colours, textures, finishes such as broken chinamosaic, tiles, and even metals.

However, cool roofs are not to be seen as an alternative to the thermal transmittancerequirement of the roof  $(U_{roof})$  as given in this code. It is encouraged to have any cool roof application over a roof assembly complying with the maximum thermal transmittance value given in the code.

### Defining a cool roof

The 'coolness' of a roof is influenced by its solar reflectance and thermal emittance.

- Solar reflectance: Solar reflectance is the ratio of solar radiation reflected by a surface to the solar radiation incident upon it. Solar reflectance is measured on a scale of 0 to 1. A reflectance value of 0 indicates that the surface absorbs all incident solar radiation, and a value of 1 denotes a surface that reflects all incident solar radiation. The term 'albedo' is often used inter-changeably with solarreflectance.
- Thermal emittance: Thermal emittance is the relative ability of a material to reradiate
  absorbed heat as invisible infrared radiation. Emittance, measured from 0 to 1, is defined
  as the ratio of the radiant flux emitted by a body to thatemitted by a black body at the same
  temperature and under the same conditions.

According to ECBC 2017 cool roof requirement, roofs with slopes less than 20 degreesshall have an initial solar reflectance of at least 0.6 and an initial emittance of 0.9.

The Solar Reflectance Index (SRI) is a term that incorporates both solar reflectance and emittance in a single value and quantifies how hot a surface would get relative to standard black and standard white surfaces. It is the ability of a material to reject solar radiation, as shown by a small temperature rise.<sup>32</sup> The SRIs of a standard black surface (having

Shakti Foundation. 2017. Cool Roofs for Cool Delhi: Design Manual. Available at http://shaktifoundation.in/wp-content/uploads/2017/06/cool-roofs-manual.pdf (accessed on 1 May 2018)

<sup>31</sup> ibid

Bureau of India Standards (BIS). 2016. National Building Code 2016. Part 11. New Delhi: BIS

reflectance of 0.05 and emittance of 0.9) and a standard white surface (of reflectance 0.8 and emittance 0.9) are taken as 0 and 100, respectively.

IGBC Green Homes requires a minimum SRI value of 78 for roof slopes with gradient ≤1:6 and 29 for steeper roof.

For more detailed information on cool roof, please refer Cool Roofs for Cool Delhi: Design Manual.<sup>33</sup>

#### Roof Gardens

In the case of roofs with roof gardens on earth fill for plantation or lawn, the thermalresistance of the earth fill can be taken into the calculation of the thermal transmittance (U value) of the roof. Some of the heat absorbed by the earth fill is also released into the atmosphere due to evapotranspiration of irrigation water from the roof garden, thus giving additional benefit.



Shakti Foundation. 2017. Cool Roofs for Cool Delhi: Design Manual. Available at http://shaktifoundation.in/wp-content/uploads/2017/06/cool-roofs-manual.pdf (accessed on 01 May 2018)